



# INCERT CERTIFICATE C-060-1789



Issued 05-12-2024 Replaces  
Expiry date 05-12-2030 Page 1 / 4

In compliance with the procedure specified in the **INCERT Scheme (Doc. Nr 005)**, Kiwa FSS products declares that the stated alarm equipment complies with the Technical standards and specifications as listed in this certificate.

Product description: Line splitter  
Trademark: Ajax  
Type designation: LineSplit Fibra  
Hardware / Software: SPF.001.MBR.001v7 / 7.62.XX.XX  
Variants: See Annex 3

Placed on the market under the name or trademark of:

Name of the manufacturer: AJAX SYSTEMS MANUFACTURING, LIMITED  
LIABILITY COMPANY  
Address: Sklyarenka, 5,  
City: 04073 Kyiv  
Country: Ukraine

This certificate is granted to:

Name of the certificate holder: Ajax Systems Cyprus Holdings Ltd.  
Address: Ifigeneias 17  
City: 2007 Nicosia  
Country: CY

Ron Scheepers  
Managing director

*This INCERT Certificate has THREE Annexes and is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standards. It does not imply an assessment on the whole production. Conformity of the produced products with the specimen tested remains on the fully responsibility of the manufacturer.*

Kiwa Nederland B.V.  
Kiwa FSS Products  
Wilmsdorf 50  
Postbus 137  
7300 AC Apeldoorn  
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>



# CERTIFICATE

**Remarks and observations**

The following conditions are applicable:

Category: Input/output module - intrusion

Security grade: 3

Environmental class: II

Equipment class: Fixed

To be used with case A, B, C or D

The x visible in the sw version stands for a digit that can change in case of minor changes.

The certified version is recorded in the certification file together with any reported minor changes.

Factory location:

AJAX SYSTEMS MANUFACTURING, LIMITED LIABILITY COMPANY

██████████

████████████████████

Ukraine

Product inspection location:

ARAS Security

Thomas Edisonweg, 5

Drunen

Netherlands

**Documentation lodged for this INCERT certificate**

Test Reports:

- Kiwa Nederland B.V.: P000406784-003-Ver.2.00, 31 October 2024
- Testalarm Praha, Ltd.: 2023 0400 Rev.1, 18 June 2024
- VZLU TEST, a.s.: P-VZLUTEST-253/23, 27 September 2023
- Abegu, A.s.: P/23/01/115, 23 August 2023

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

**Technical Standards and Specifications**

The product shows no non-compliances with:

T 031+A1+A2	August, 2022
-------------	--------------

**Applied Standards**

EN 50131-3	March, 2009
EN 50130-5	June, 2011
EN 50130-4+A1	October, 2014
EN 50131-1+A1+A2+A3	June, 2020

**The product as described in this certificate includes the following type designations**

- Product description: Line splitter  
- Trademark: Ajax  
- Type designation: LineSplit Fibra  
- Hardware version: SPF.001.MBR.001v7  
- Software version: 7.62.XX.XX

- Product description: Line splitter  
- Trademark: Ajax  
- Type designation: Superior LineSplit Fibra  
- Hardware version: SPF.001.MBR.001v7  
- Software version: 7.62.XX.XX